

Titanium 97+ (Small)


RECESSED DOWNLIGHT 

 Class II 220-240V ~ 50/60Hz	Power 11 Watts	IP Rating 44 (Roomside)	Material Aluminium	Warranty 7 Years				
--	--------------------------	-----------------------------------	------------------------------	----------------------------	---	---	---	---

⚠ CAUTION – Must Be Installed By A Licensed Electrician

Please read instruction manual on **both** sides carefully before installing luminaire.

- Please read instructions for installation of luminaire provided below. Safety of this luminaire and warranty will be voided unless followed.
- Installation and operation of this luminaire must be within accordance with national safety regulations. Unios™ does not warrant any liability when damage is caused by misuse or improper installation.
- This luminaire is void of warranty if any part has been modified. Please visit unios.com/warranty for more information.
- Over-voltage protection units should be installed to prevent electronic control gear from failing due to electrical spikes, e.g. from switching of inductive loads.



Installation Instructions


- 1 Must be installed by a licensed electrician.
- 2 Before installing, make sure the power supply is switched off.
- 3 Follow the steps in the figure shown for installation:
 - A. Cut a diameter of 76mm.
 - B. Connect electronic control gear plug to female power socket (not included).


Warning: Please ensure luminaire is connected to electronic control gear prior to connecting mains power. Not doing so will cause damage to the luminaire/electronic control gear.

 - C. Hold clips in place and push luminaire into cut-out.
 - D. Activate power at the source once completed.

Minimum clearance for luminaire - In accordance with AS/NZS 60598.2.2:2016

⚠ Risk of Fire – Required clearance from structure members and building elements. Details below:

Description	Dimensions	Building element above fitting	
A Height clearance to building element (HCB)	0mm	Barrier required for loose fill insulation or loose combustible materials	 <p>Please ensure electronic control gear is fixed above any insulation</p>
B Side clearance to building element (SCB)	0mm		
C Side clearance to Insulation (SCI)	0mm		
D Side clearance to Control Gear (SCG)	50mm		



IC Luminaire

A recessed luminaire that can be abutted against normally flammable materials including building insulation, and can be covered in normal use. Building elements building insulation or debris have limited access to the heated parts of the luminaire.

FOR WARRANTY INFORMATION VISIT WWW.UNIOS.COM/WARRANTY

Please read these installation instructions carefully before installing this luminaire. The luminaire is designed for installation in accordance with relevant Australian Standards (AS/NSZ 3000). Installation of this luminaire must comply with local and national regulations. If luminaire is not installed according to the instructions, the warranty for the luminaire may be void.

ENQUIRIES

+61 8 9248 1888
sales@unios.com

Additional Accessories

Supplied separately.



Concrete Fascia
(100mm)


Concrete Ceilings

For installation into concrete canisters, the supplied concrete canister rubber sleeves must be used on the spring clips for added grip.

Wiring

This luminaire must be installed in conjunction with remote electronic control gear.

Warning: Please ensure luminaire is connected to electronic control gear prior to connecting mains power. Not doing so will cause damage to the luminaire/electronic control gear.



Dimming

This luminaire can be dimmed. Unios™ recommends a phase-cut dimmer optimised for LED technology.

Cleaning

Before cleaning, disconnect from mains supply and allow luminaire to cool.

Regular cleaning of the luminaire is **strongly recommended**. In harsher conditions, it is recommended that a strict cleaning schedule is in place to ensure no eroding chemicals are left on the surface for long periods. To clean luminaire, only use a damp, microfibre cloth. A dilute solution of a mild pH-neutral liquid detergent can be used for resistant dirt (Solvents must not be used). Please note surface of luminaire must be wiped down with a clean damp microfibre cloth to ensure no residue is left on the surface. Take care not to damage the surface of the luminaire. Do not use high pressure cleaners.

Corrosion Protection

It is important to note that care must be taken during installation or maintenance to ensure that the surface of the luminaire is not damaged. Any damage, which is exposed to moisture will result in corrosion occurring.

Please also note that any chemical applications on the luminaire will cause corrosion of the surface of the luminaire and will void the warranty.

Cleaning of Luminaire Lens

The luminaire lens or glass can be cleaned with glass specific cleaning agents that are ph-neutral, alcohol-free and non-abrasive. Always use a damp microfibre cloth and take care not to damage any seals surrounding the glass.



Class II

Luminaire in which protection against electric shock is provided by double insulation or reinforced insulation.



IP44 (Roomside)

Protected against solid bodies no larger than 1mm and water splashed from any direction.




AC

220-240V 50-60Hz AC Supply.



Outdoor Use

This luminaire is suitable for outdoor use, taking in consideration of the IP rating.



IC Luminaire

A recessed luminaire that can be abutted against normally flammable materials including building insulation, and can be covered in normal use. Building elements building insulation or debris have limited access to the heated parts of the luminaire.

FOR WARRANTY INFORMATION VISIT WWW.UNIOS.COM/WARRANTY

Please read these installation instructions carefully before installing this luminaire. The luminaire is designed for installation in accordance with relevant Australian Standards (AS/NSZ 3000). Installation of this luminaire must comply with local and national regulations. If luminaire is not installed according to the instructions, the warranty for the luminaire may be void.

ENQUIRIES

+61 8 9248 1888
sales@unios.com